



Number	KIP-16706/E	Replaces	KIP-15900E
Issue date	18-12-2020	Contract number	3600
Report number	141201097/6	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
PIN	0476CQ1097	Module	B (Type testing)

EC TYPE-EXAMINATION CERTIFICATE (BED/R813)

Kiwa Cermet Italia, notified body for council Directive 92/42/EC, hereby declares that the Central heating condensing boiler, type(s):

**MYDENS 15P, MYDENS 15C, MYDENS 15B, MYDENS 24P, MYDENS 24C,
MYDENS 24B, MYDENS 34P, MYDENS 34C, MYDENS 34B, MYDENS 50A,
MYDENS 50C, MYDENS 60A, MYDENS 60C, HYB MY 24P F6 C,
HYB MY 15P ***, HYB MY 24P ***, HYB MY 34P ***,
HYB MY 15B ***, HYB MY 24B ***, HYB MY 34B ***,
HYB MY 15C ***, HYB MY 24C ***, HYB MY 34C *****

Manufacturer

COSMOGAS S.r.l.
Via L. Da Vinci, 16
47014, Meldola (FC), Italy

meet the requirements regarding useful efficiencies according to **article 4 of commission regulation (EU) No. 813/2013** and as described in the **Directive 92/42/EEC on efficiency requirements**.

Reference standard:

EN 15502-1:2012+A1:2015
EN 15502-2-1:2012+A1:2016

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

CERTIFICATE

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di
direzione e coordinamento di Kiwa Italia
Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)
Unità locale

Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it

www.kiwacermet.it

GASTEC

Chief Operating Officer
Giampiero Belcredi



Number	KIP-16706/E	Page	1 of 8
Issue date	18-12-2020	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	141201097/6	Module	B (Type testing)
PIN	0476CQ1097		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
COSMOGAS

Specifications:
Model(s):
MYDENS 15P,
HYB MY 15P ***

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	13,6	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	n.t.	kW
Useful efficiencies			
At rated heat output and high-temperature regime (*)	η ₄	86,9	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	96,8	%
Useful efficiencies - NCV			
At rated heat output and high-temperature regime (*)	η ₁₀₀	96,5	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	107,5	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

Calculated values are based on gross calorific value (reference conditions: 15 °C, 1013,25 mbar)

*** See model breakdown in report n°141201097/6 for detailed description of the models

Number	KIP-16706/E	Page	2 of 8
Issue date	18-12-2020	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	141201097/6	Module	B (Type testing)
PIN	0476CQ1097		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
COSMOGAS

Specifications:

Model(s):

MYDENS 15B
MYDENS 15C
HYB MY 15B ***
HYB MY 15C ***

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	no ⁽¹⁾

⁽¹⁾ The boiler can be connected to an external tank for domestic hot water production

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	13,6	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	n.t.	kW
Useful efficiencies			
At rated heat output and high-temperature regime (*)	η ₄	86,9	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	96,8	%
Useful efficiencies - NCV			
At rated heat output and high-temperature regime (*)	η ₁₀₀	96,5	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	107,5	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

Calculated values are based on gross calorific value (reference conditions:15 °C, 1013,25 mbar)

*** See model breakdown in report n°141201097/6 for detailed description of the models

Number	KIP-16706/E	Page	3 of 8
Issue date	18-12-2020	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	141201097/6	Module	B (Type testing)
PIN	0476CQ1097		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
COSMOGAS

Specifications:

Model(s):
MYDENS 24P
HYB MY 24P ***

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	24,8	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	n.t.	kW
Useful efficiencies			
At rated heat output and high-temperature regime (*)	η ₄	87,6	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	97,7	%
Useful efficiencies - NCV			
At rated heat output and high-temperature regime (*)	η ₁₀₀	97,3	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	108,5	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

Calculated values are based on gross calorific value (reference conditions:15 °C, 1013,25 mbar)

*** See model breakdown in report n°141201097/6 for detailed description of the models

Number	KIP-16706/E	Page	4 of 8
Issue date	18-12-2020	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	141201097/6	Module	B (Type testing)
PIN	0476CQ1097		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
COSMOGAS

Specifications:

Model(s):

MYDENS 24B

MYDENS 24C

HYB MY 24B ***

HYB MY 24C ***

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	no ⁽¹⁾

⁽¹⁾ The boiler can be connected to an external tank for domestic hot water production

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	24,8	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	n.t.	kW
Useful efficiencies			
At rated heat output and high-temperature regime (*)	η ₄	87,6	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	97,7	%
Useful efficiencies - NCV			
At rated heat output and high-temperature regime (*)	η ₁₀₀	97,3	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	108,5	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

Calculated values are based on gross calorific value (reference conditions:15 °C, 1013,25 mbar)

*** See model breakdown in report n°141201097/6 for detailed description of the models

Number	KIP-16706/E	Page	5 of 8
Issue date	18-12-2020	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	141201097/6	Module	B (Type testing)
PIN	0476CQ1097		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
COSMOGAS

Specifications:

Model(s):
MYDENS 34P
HYB MY 34P ***

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	30,9	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	n.t.	kW
Useful efficiencies			
At rated heat output and high-temperature regime (*)	η ₄	87,2	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	96,3	%
Useful efficiencies - NCV			
At rated heat output and high-temperature regime (*)	η ₁₀₀	96,8	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	107,0	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

Calculated values are based on gross calorific value (reference conditions: 15 °C, 1013,25 mbar)

*** See model breakdown in report n°141201097/6 for detailed description of the models

Number	KIP-16706/E	Page	6 of 8
Issue date	18-12-2020	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	141201097/6	Module	B (Type testing)
PIN	0476CQ1097		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
COSMOGAS

Specifications:

Model(s):

MYDENS 34B

MYDENS 34C

HYB MY 34B ***

HYB MY 34C ***

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	no ⁽¹⁾

⁽¹⁾ The boiler can be connected to an external tank for domestic hot water production

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	30,9	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	n.t.	kW
Useful efficiencies			
At rated heat output and high-temperature regime (*)	η ₄	87,2	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	96,3	%
Useful efficiencies - NCV			
At rated heat output and high-temperature regime (*)	η ₁₀₀	96,8	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	107,0	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

Calculated values are based on gross calorific value (reference conditions:15 °C, 1013,25 mbar)

*** See model breakdown in report n°141201097/6 for detailed description of the models

Number	KIP-16706/E	Page	7 of 8
Issue date	18-12-2020	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	141201097/6	Module	B (Type testing)
PIN	0476CQ1097		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
COSMOGAS

Specifications:

Model(s):
MYDENS 50A
MYDENS 50C

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	no ⁽¹⁾

⁽¹⁾ The boiler can be connected to an external tank for domestic hot water production

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	48,5	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	16,2	kW
Useful efficiencies			
At rated heat output and high-temperature regime (*)	η ₄	87,8	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	96,5	%
Useful efficiencies - NCV			
At rated heat output and high-temperature regime (*)	η ₁₀₀	97,5	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	107,2	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

Calculated values are based on gross calorific value (reference conditions: 15 °C, 1013,25 mbar)

*** See model breakdown in report n°141201097/6 for detailed description of the models

Number	KIP-16706/E	Page	8 of 8
Issue date	18-12-2020	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	141201097/6	Module	B (Type testing)
PIN	0476CQ1097		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
COSMOGAS

Specifications:

Model(s):
MYDENS 60A
MYDENS 60C

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	no ⁽¹⁾

⁽¹⁾ The boiler can be connected to an external tank for domestic hot water production

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	56,1	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	n.t.	kW
Useful efficiencies			
At rated heat output and high-temperature regime (*)	η ₄	87,5	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	96,4	%
Useful efficiencies - NCV			
At rated heat output and high-temperature regime (*)	η ₁₀₀	97,2	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	107,0	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

Calculated values are based on gross calorific value (reference conditions:15 °C, 1013,25 mbar)

*** See model breakdown in report n°141201097/6 for detailed description of the models

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia. Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.